

ADDENDUM NO. 2

CITY OF OLATHE, KANSAS
143rd SANITARY SEWER LAKESHORE MEADOWS WEST
CITY PROJECT NO.: 1-B-001-07

This addendum is to change the following items:

1. Bid Time extended. Revise Notice to Bidders to read:
 - a. “Sealed bids will be received at the office of the City Clerk, at City Hall, 100 East Santa Fe, in Olathe, Kansas, until 2:00 p.m. local time, on October 22, 2008 for the construction of 143rd Sanitary Sewer, Lakeshore Meadows West, Project 1-B-001-07.”

2. Clarifications:
 - a. PVC used for this project shall meet SOLID WALL ASTM F679. PS = 46 psi
 - b. ASTM F794 will not be accepted.
 - c. Bid Item 10. Sectional Plate Casing shall be allowed.